

TEST RESULTS

Microbiological	Highest Number of Positive Samples		MCL		MCLG	Likely Source of Contamination		Violations Present
No Detected Results were Found in the Calendar Year of 2024								
Lead and Copper	Monitoring Period	90 th Percentile	Range	Unit	AL	Sites Over AL	Likely Source of Contamination	
COPPER, FREE	2020 - 2022	0.169	0.0186 - 0.671	ppm	1.3	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.	
LEAD	2020 - 2022	0.686	0 - 1.36	ppb	15	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.	
Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination	
ARSENIC	3/18/2024	1.6	1.6	ppb	10	0	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.	
BARIUM	7/24/2023	0.213	0.213	ppm	2	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.	
CHROMIUM	7/24/2023	3.5	3.5	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.	
FLUORIDE	7/24/2023	0.285	0.285	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge.	
NITRATE-NITRITE	10/16/2024	11	0.493 - 11	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
SELENIUM	4/10/2024	41.1	2.6 - 41.1	ppb	50	50	Erosion of natural deposits	
Radiological Contaminants		Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination
COMBINED RADIUM (-226 & -228)		12/16/2024	1.69	1.69	pCi/L	5	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U		1/30/2024	9.02	9.02	pCi/L	15	0	Erosion of natural deposits
RADIUM-228		12/16/2024	1.69	1.69	pCi/L		0	Erosion of natural deposits
Unregulated Water Quality Data		Collection Date	Highest Value		Range		Unit	Secondary MCL
SULFATE		9/12/2022	258		80.6 - 258		mg/L	250
During the 2024 calendar year, we had the below noted violation(s) of drinking water regulations.								
Violation Type		Category			Analyte		Compliance Period	
No Violations Occurred in the Calendar Year of 2024								

The City of Humphrey has taken the following actions to return to compliance with the Nebraska Safe Drinking Water Act:

Additional Required Health Effects Language:

Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

There are no additional required health effects violation notices.

The City of Humphrey lead service line inventory has been prepared and can be accessed here: City of Humphrey Office 203 Elm St